

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

# Pliteq, Inc

131 Royal Group Crescent, Vaughan, ON, Canada

For the following product(s):

## Underlayments:

GenieMat® DH, GenieMat® RAIL, GenieMat® GBV, GenieMat® FIS, GenieMat® RST, GenieMat® FFNP, GenieMat® FF, GenieMat® FIT, Pliteq TREAD™ Grip, Pliteq TREAD™ Cushion

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

## FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.1

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Between 0.5 – 5.0 mg/m<sup>3</sup> (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-03555

Valid from: April 1, 2023 to March 31, 2024

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



ANSI National Accreditation Board  
ACCREDITED

ISO/IEC 17065

PRODUCT CERTIFICATION  
BODY



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Executive Vice President  
SCS Global Services  
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA